



NOTES:

1. NOT ACCEPTABLE FOR USE IN TRAFFIC AREAS OR AREAS SUBJECT TO FLOODING.
2. VACUUM OR EXFILTRATION TESTING SHALL BE USED. VACUUM TESTING SHALL MEET THE SAME STANDARD FOR CONCRETE MANHOLES. EXFILTRATION TESTING SHALL HAVE NO LEAKAGE WITHIN 1 HOUR.
3. "AquaBlok" WASTEWATER ACCESS CHAMBERS MAY BE SUBSTITUTED. TRAFFIC BEARING BOXES WOULD BE REQUIRED IF INSTALLED IN TRAFFIC AREAS. TESTING OF "AquaBlok" SHALL BE BY APPLICABLE PLUMBING CODE FOR SEWER LATERALS.
4. 2' DIA. CONCRETE WELL CASING 3000 PSI MAY BE SUBSTITUTED FOR ULTRA-RIB PIPE. ANY VERT. JOINTS IN THE CASING PIPE MUST BE BY BELL & SPIGOT CONNECTION WITH MASTIC.
5. STANDARD 4' DIAMETER MANHOLES SHALL BE USED WHERE DEPTH EXCEEDS 5'.

REVISIONS				SAMPLING STRUCTURE DETAIL	DRAWING S-06
NO.	DATE				
ORIGINAL	12/01/06				