

# MONTGOMERY COUNTY PUBLIC SERVICE AUTHORITY

## ADDENDUM NO. 1

July 1, 2016

### WALNUT CREEK SANITARY SEWER PUMP STATION REPLACEMENT PROJECT

BID NO. 17-07

This Addendum No. 1 shall be attached to and made a part of the Contract Documents for the above referenced project dated June 9, 2016. Bidders are advised to acknowledge receipt of this Addendum No. 1 on page BF-2 of the BID FORM.

#### **ITEM NO. 1:**

**REF: Specifications Section 03400; PRECAST CONCRETE:**

#### **ADD:**

2.6 EXTERIOR COATING; Exterior surfaces of all concrete sections shall have two coats (minimum 16 dry mils) of polymer modified asphalt emulsion, Seaboard Asphalt Products Co. EM-13 or equal or coal tar epoxy, Koppers Co. Bitumastic 300-M or equal.

#### **ITEM NO. 2:**

**REF: Specifications Section 11310;**

2.3 SUBMERSIBLE NON-CLOG SEWAGE PUMPS; "C. General: ... *60 feet of power cable...*"

#### **CHANGE TO:**

2.3 SUBMERSIBLE NON-CLOG SEWAGE PUMPS; "C. General: ... *40 feet of power cable...*"

#### **ITEM NO. 3:**

**REF: Specifications Section 11310;**

2.4 PUMP CONTROLS; "A. General: *OWNER* shall furnish..."

#### **CHANGE TO:**

2.4 PUMP CONTROLS; "A. General: *CONTRACTOR* shall furnish..."

**ITEM NO. 4:**

**REF: Specifications Section 11310;**

2.4 PUMP CONTROLS; “C. Level controls: *One hundred (100) feet of cable shall be provided*”

**CHANGE TO:**

2.4 PUMP CONTROLS; “C. Level controls: *Fifty (50) feet of cable shall be provided*”

**ITEM NO. 5:**

**REF: Specifications Section 11310;**

2.5 NON-AUTOMATIC (MANUAL) TRANSFER SWITCH

**ADD:**

D. Transfer switch receptacle assembly shall be Cooper Crouse-Hinds “Arktite” Style 1, 4-pole, hub size 2 with spring door, catalog #AREA10416, ATP312 receptacle, or approved equal.

**ITEM NO. 6:**

**REF: Specifications Section 11310;**

**ADD:**

3.3 ELECTRICAL; Installation shall meet all applicable electrical codes relative to fault current rating for the provided equipment. Main fault protection shall be rated at 65,000 AIC. Fault protection shall be fully rated and not series rated. Time delay fault protection shall be provided for pump motors.

**ITEM NO. 7:**

**REF: Construction Plan Sheet 3 of 4 – ELECTRICAL PANEL LAYOUT and PUMP STATION ONE-LINE DIAGRAM;**

**CHANGE TO:**

ELECTRICAL PANEL LAYOUT and PUMP STATION ONE-LINE DIAGRAM as shown on attached file SHEET3A.7.1.16.

NOTE: CONTRACTOR shall furnish fully functioning and properly sized electrical and pump components which meets all applicable codes.

**- END OF ADDENDUM NO. 1 -**