

INVITATION FOR BID # 18-10
 ADDENDUM # 1
 COUNTY OF MONTGOMERY
 PURCHASING DEPARTMENT
 755 ROANOKE STREET, Suite 2C
 CHRISTIANSBURG, VA 24073-3179

DATE		BID OPENING DATE AND HOUR	SEALED BID	BID NUMBER
November 21, 2017		November 28, 2017 3:00 P.M.	Yes	18-10

ADDRESS ALL INQUIRIES AND CORRESPONDENCE TO: Heather Hall
TELEPHONE NUMBER: (540) 382-5784

INVITATION FOR BID/ADDENDUM # 1 FAX NUMBER: (540) 382-5783

B I D D E R	SPECIAL INSTRUCTIONS 1. To avoid being disqualified, sealed bids must be returned in an envelope with the bid number and opening date indicated on the outside of the envelope. 2. FAXED RESPONSES WILL NOT BE ACCEPTED FOR SEALED BIDS. 3. Bids must be signed in ink. Failure to do so may result in bid disqualification. 4. Bids will be received in Purchasing Department until bid opening date and hour.				
#	DESCRIPTION: Montgomery County Government Center IT Fiber Cable Implementation	QUANTITY	UNIT	UNIT PRICE	EXTENDED PRICE
1	<p>The following questions and answers are being shared for all parties to have knowledge of questions asked and answered on this project.</p> <p>1. Are you expecting all of the fiber parts for termination to be worked into the quote for example connectors, adapter panels, and rackmount panels?</p> <p>We are expecting terminated cables into patch panels, so you would need to provide the adapter panels and rackmount panels; the County will provide the connectors and transceivers.</p> <p>2. Will the County provide the ladder rack and cable management for the two-post racks?</p> <p>The County will provide a ladder rack and all vertical and horizontal cable management. The contractor will need to terminate the fiber into patch panels; the County will provide connectivity to the copper network as part of Phase 3 – Copper Cable Implementation.</p> <p>3. What type of Multi-Mode fiber? Is it 62.5 or 50 micron?</p> <p>50 micron</p> <p>4. Is Inner-duct required, if so, are you OK with pulling the multimode and single mode fiber in the same inner-duct?</p>				

	<p>Inner-duct is required and you can pull both multi-mode and single-mode fiber in the same inner-duct</p> <p>5. Please confirm what type of fiber connectors you want. SC connectors were mentioned on Friday but I wanted to confirm that.</p> <p>SC Connectors</p> <p>6. Are you OK with terminating the multimode and single mode fiber in the same fiber tray?</p> <p>Yes</p>				
2	The bid opening date and hour remains November 28, 2017 at 3:00 p.m.				
3	All other terms and conditions remain the same.				

ATTACHED TO THIS FORM ARE PRINTED TERMS AND CONDITIONS. THE INVITATION FOR BID, THE BID, AND ANY MODIFICATION OR ADDITIONS TO EITHER, TOGETHER WITH THE PURCHASE ORDER SHALL CONSTITUTE AN ENTIRE INTEGRATED CONTRACT. IN ACCORDANCE WITH THIS INVITATION FOR BID AND SUBJECT TO ALL CONDITIONS IMPOSED HEREIN AND IN ATTACHMENTS, THE UNDERSIGNED OFFERS AND AGREES TO FURNISH THE ITEM(S) FOR THE PRICE OPPOSITE EACH ITEM.

FIRM NAME (PRINT)		F.I.N. NUMBER	
STREET ADDRESS	CITY, STATE, ZIP	DELIVERY DATE	TERMS N30
PRINT NAME/TITLE		SIGNATURE (INK)	DATE
TELEPHONE NUMBER	TOLL FREE TELEPHONE NUMBER	FACSIMILE NUMBER	